

PEF  
GPS  
MLD

## New York State Department of Environmental Conservation

## MEMORANDUM

STRAIGHTEN  
OUT  
w/ BRUCE

TO: Buffalo Region Office #9, Attn: Martin Doster  
 FROM: Mr. Loveridge, By: Mr. Bruce  
 SUBJECT: Great Lakes Carbon  
 Niagara Falls (C), Niagara Co.  
 NY 000 0906  
 DATE: February 9, 1983

Above subject permit was modified December 13, 1982 based on the following test results run on 001 by Region 9 office, and reported to the central office.

Dinitro-Cresol  
 Methylene Chloride  
 Lead  
 Zinc

25 mg/l  
 16 mg/l  
 300 mg/l  
 50 mg/l

} should all  
 be ug/l  
 per telecon w/ w. Bruce

Dinitro-Cresol and Methylene Chloride were below water quality and technology-based requirements, and using the policy of 5x the concentration found or .1 mg/l, (whichever is largest is set as the limit with limited monitoring).

Zinc and lead are limited as 1.0 and 0.4 mg/l respectively, which are limits for BAT.

WAB/ag

*[Signature]*

2,4-Dimethylphenol

323709

